



CONTRACTOR SHALL PROVIDE AND INSTALL ALL FITTINGS, VALVING AND ETC. ON RISER CAP AS REQUIRED FOR TESTING BY UTILITIES DEPT.

PIPE SHALL BE WRAPPED W/POLYWRAP OR BUILDERS FELT WHERE IT MEETS CONC.

1.0' MIN.

FINISHED GRADE LINE

CONC. FLOOR

5.0' MINIMUM

3/4" REDI-RODS (TYP.) AS REQUIRED

NEW DUCTILE WATER SERVICE

SERVICE VALVE

TEE OR TAPPING SLEEVE. BLOCK AS PER STANDARD PLAN 134

THRUST BLOCK AS PER STANDARD PLAN 134.

NOTE:  
IF SERVICE PIPE ENTERS THE BUILDING HORIZONTALLY THE INSTALLATION MUST BE RETAINED FROM THE INTERIOR FLANGE UPSTREAM TO THE VALVE AT THE WATER MAIN.

GENERAL NOTES:

1. ALL COMMERCIAL WATER SERVICES LARGER THAN 2" IN DIA. SHALL BE DUCTILE IRON FROM SERVICE VALVE TO METER.
2. DETAILED PLANS FOR NEW AND REPLACEMENT SERVICE LINES SHALL BE PREPARED IN ACCORDANCE WITH THE REQUIREMENTS OF THE "SITE PLAN GUIDELINES FOR PRIVATE DOMESTIC AND PRIVATE FIRE SERVICE MAINS, LARGER THAN 2" DIA." THE WORKING PLANS SHALL BE SUBMITTED FOR REVIEW TO THE AUTHORITY HAVING JURISDICTION BEFORE ANY EQUIPMENT IS INSTALLED OR REMODELED. THE CITY OF GRAND ISLAND UTILITIES DEPARTMENT, BUILDING DIVISION, AND THE CITY OF GRAND ISLAND FIRE DEPARTMENT SHALL BE REFERENCED AS THE AUTHORITY HAVING JURISDICTION (AHJ).

THIS DOCUMENT WAS ORIGINALLY SEALED AND ISSUED BY JAMIE L. ROYER E-17387, ON 1-8-2024. THIS MEDIA SHOULD NOT BE CONSIDERED A CERTIFIED DOCUMENT AND SHOULD BE USED FOR REFERENCE ONLY.