





- ALL THRUST BLOCKS TO BE TYPE 47-B MODIFIED POURED CONCRETE AS PER DIVISION II; "CONCRETE PAVING SPECIFICATIONS"; AND DIVISION VI "WATER MAINS".
- 2. ALL CONCRETE BLOCKING SHALL BE INSTALLED IN SUCH A MANNER THAT ALL PIPE AND FITTING JOINTS ARE ACCESSIBLE.
- 3. ALL FITTINGS ARE TO BE WRAPPED IN 8 MIL POLYETHYLENE.
- 4. ALL THRUST BLOCKS ARE TO BE POURED AGAINST UNDISTURBED SOIL.
- 5. IF SOIL OTHER THAN SANDY SOIL IS DISCOVERED DURING EXCAVATION, THE THRUST BLOCK SIZE SHALL BE VERIFIED BY THE ENGINEER.
- 6. TAPPING SLEEVES SHALL BE TREATED AS A TEE AND BLOCKED ACCORDINGLY



REVISED: 1/03/2019 DRAWN BY: TDZ CHECKED BY: R.L.S. CONCRETE BLOCKING FOR FITTINGS HORIZONTAL BLOCKING PLAN 134 1 of 6