



NOTES:

1. IF VERTICAL ADJUSTMENT OF 2.0' OR LESS IS REQUIRED TO BRING FIRE HYDRANT TO GRADE, THE PIPE NIPPLE BETWEEN REDUCER AND FIRE HYDRANT SHALL BE REPLACED WITH RETAINED GRADE-LOK OFFSET FITTING. IF VERTICAL ADJUSTMENT REQUIRED IS GREATER THAN 2.0' THEN 2 INVERTED 6"x45° BENDS WITH RETAINER GLANDS SHALL BE USED FOR ADJUSTMENT.
2. ALL MECHANICAL JOINTS DOWNSTREAM OF THE BELL JOINT BLOCK SHALL BE INSTALLED WITH RETAINER GLANDS
3. NO SLIP JOINTS MAY BE INSTALLED DOWNSTREAM OF THE BELL JOINT BLOCK.

THIS DOCUMENT WAS
 ORIGINALLY SEALED AND
 ISSUED BY RYAN L. SCHMITZ
 E 15818, ON 1-6-2023. THIS
 MEDIA SHOULD NOT BE
 CONSIDERED A CERTIFIED
 DOCUMENT AND SHOULD BE
 USED FOR REFERENCE ONLY.

 <p>CITY OF GRAND ISLAND UTILITIES DEPARTMENT</p>	REVISED: 1/6/2023 DRAWN BY: TDZ CHECKED BY: R.L.S.	<p>TEMPORARY FIRE HYDRANT ON DEAD- END</p>	<p>PLAN 159</p>
---	--	---	-------------------------------------