

UTILITIES DEPARTMENT – PLATTE GENERATING STATION  
CITY OF GRAND ISLAND, NEBRASKA

BOILER INSPECTION AND REPAIR - FALL 2020 OUTAGE  
C129417

**ADDENDUM # 2 TO BID DOCUMENTS**

ISSUE DATE: August 6, 2020

**ADDENDUM #2: Clarification to Boiler Inspection and Repair - Fall 2020 Bid Documents**

In the Detailed Specification (page 15 of 29) under X. SERVICE RATES: The bid data form has a lump sum for the entire project. A separate sheet shall show the following breakdown: items 1 -4 listed in Section X, along with item number 5 to be added. (Screen shot of Service Rates section below)

ADD : 5- Lump sum for replacement of coal nozzles, aux air nozzles, and COFA nozzles.

In the Detailed Specification (page 14 of 29) under -

IV. INSPECTIONS AND REPAIRS:

D. Attachments:

1. BD-1 Blowdown line *The drawing showing the connections to the blowdown line is incorrect. An additional 1" line and 2" line are located near the blowdown tank. The 2" line furthest from the blowdown tank is capped and will not be needed.*

X. SERVICE RATES: The Contractor shall provide lump sum T&M not-to-exceed pricing for the scope as specified with a breakout of separate lump sum pricing for each of:

- 1 - Firm price for all Mobilization, Demobilization, Tools, Equipment, supplies, PPE, expendables, supervision and project management, overhead, fixed costs and expenses.
- 2 – A Lump sum T&M cost of labor for one crew working 10 hours per day October 20-November 14, 2020. For bidding purposes, the crew shall consist of 1 Superintendent, 1 BM General Foreman and 3 BM Journeymen. *[Addendum #1 – The number of days shall be 5 days a week for 4 weeks or 20 days at 10 hours per day. 8/6/2020]*
- 3- Provide T&M rate sheets that are the basis of the costs above and which will further be used for all billing, including all modifications to the labor crew required during the performance of the work.
- 4- Firm price for Materials and labor to replace the 45' of 6" blowdown line as shown on drawing BD-1.
- 5-*Lump sum for replacement of coal nozzles, aux air nozzles, and COFA nozzles. [Addendum #2]*

\*\*\*\*\*

Said Addendum #2 is hereby incorporated into the Boiler Inspection and Repair- Fall 2020 Outage Bid specification Package and shall be considered in the final Contract.

***Please acknowledge this Addendum on your BID DATA FORM when submitting your Bid and Acknowledge Receipt of same to [knagel@qiud.com](mailto:knagel@qiud.com).***