

UTILITIES DEPARTMENT – PLATTE GENERATING STATION
CITY OF GRAND ISLAND, NEBRASKA

ADDENDUM # 1 TO BID DOCUMENTS

ELECTROSTATIC PRECIPITATOR TRANSFORMER-RECTIFIER

ISSUE DATE: May 26, 2021

INSTRUCTIONS: In the Detailed Specification – Request for Bids, Section 2.5 Installation, (Page 19 of 31), please remove the line items “Removing Existing Current Limiting Reactor” and “Installing New Current Limiting Reactor” from your consideration in preparing your bid for the above project.

2.5 Installation

The Contractor shall be responsible for the installation of the T/R sets. The installation shall include, but not be limited to:

- Removing Existing T/R Sets
- Modifying Existing Secondary Oil Containment
- ~~Removing Existing Current Limiting Reactor~~
- Installing New T/R Sets
- ~~Installing New Current Limiting Reactor~~
- Integrating T/R Sets with existing precipitator controls
- Ensuring proper connections to electric bus
- Ensuring Airtight seal with bus ducts

No other changes.

Said Addendum #1 is hereby incorporated into the Electrostatic Precipitator Transformer-Rectifier bid specification and shall be noted in the final Contract.

Please acknowledge this Addendum on your BID DATA FORM and CHECKLIST.