



THIS DOCUMENT WAS  
 ORIGINALLY SEALED AND  
 ISSUED BY JAMIE L ROYER  
 E-17387, ON 1-8-2024. THIS  
 MEDIA SHOULD NOT BE  
 CONSIDERED A CERTIFIED  
 DOCUMENT AND SHOULD BE  
 USED FOR REFERENCE ONLY.

- NOTES:
1. TRACER WIRE SHALL BE MINIMUM 14 GAUGE ISOLATED WIRE AND BLUE IN COLOR
  2. TRACER WIRE TO BE TAPED TO SERVICE PIPE AT 5' INTERVALS
  3. TERMINATIONS UNDER GROUND SHALL BE COATED WITH A DI-ELECTRIC CORROSION INHIBITOR.